

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

October 13, 2008

DESIGN HOMES, INC. KURT SMITH 600 N MARQUETTE RD PO BOX 239 PRAIRIE DU CHIEN WI 53821

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: DESIGN HOMES, INC.

Product Name: PREFABRICATED PLUMBING

Model Number(s): PLB18 Product File No: 20080575

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2014.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on February 7, 2004 under product file number 20030603.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030603.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

During the period that this product approval is in effect, it is the responsibly of the submitting party to inform Commerce of any changes to the contact information or an address change. **Renewals will be sent to the address of record.**

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742

Fax: 608-267-9566

E-mail: Jerry.Thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 08057501.DOC